



Government Of West Bengal
Office Of The Divisional Fire Officer, Paschim Bardhaman
West Bengal Fire & Emergency Services
Bhangakhuti, Purba Burdwan, P.O.-: Rajbati, Pin :- 713104

Memo no.: IND/WB/FES/20182019/32671

Date: 28-09-2023

From:

Divisional Fire Officer, Paschim Bardhaman
West Bengal Fire & Emergency Services

To: ODM International School, Under Durgapur Ispat Peoples Society.

Surya Sen Sarani, Phase-II, City Center, South G.T Road, Holding no. N/22, Ward no. 22, Mouza Faridpur, J.L no. 74, C.S Plot no. 3027, and bulk, P.O Palashdiha, P.S Durgapur, Paschim Bardhaman, 713208

Sub: Renewal of Fire Safety Certificate for the existing construction of G+1 storied building under group educational, name as "ODM International School, under Durgapur Ispat Peoples Society" at, Surya Sen Sarani, Phase-II, City Center, South G.T Road, Holding no. N/22, Ward no. 22, Mouza Faridpur, J.L no. 74, C.S Plot no. 3027, and bulk, P.O Palashdiha, P.S Durgapur, Paschim Bardhaman, 713208.

This is in reference to your application no. 0125191209100103 dated 28-09-2023 regarding the Renewal of Fire Safety Certificate for the existing construction of G+1 storied building under group educational, name as "ODM International School, under Durgapur Ispat Peoples Society" at, Surya Sen Sarani, Phase-II, City Center, South G.T Road, Holding no. N/22, Ward no. 22, Mouza Faridpur, J.L no. 74, C.S Plot no. 3027, and bulk, P.O Palashdiha, P.S Durgapur, Paschim Bardhaman, 713208.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

1. Driveway must be free of any type of obstruction for easy movement of fire appliances. No parking will be allowed on the drive way.
2. The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.
3. To eliminate risk of fire hazard, good housekeeping both for inside and outside of the building shall be strictly maintained.
4. A fire control room including a closed-circuit TV system will have to be maintained which observe all floor of the building.

Principal
ODM International School
Durgapur

Manager
ODM International School
Durgapur


5. Driveway must be free of any type of obstruction for easy movement of Fire Appliances.
6. No parking will be allowed on the Driveway.
7. The interior finish decoration of the building shall be made with low flame spread material confirming to the I.S. Specification.
8. To eliminate risk of fire hazards, good house-keeping both for inside and outside of the buildings shall be strictly maintained.
9. Existing Electrical wiring of the whole industry shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling and ducts.
10. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable areas of the site.
11. The employees and security staffs shall be conversant with installed Fire Fighting Equipments of the building and to operate in the event of Fire and Testing.
12. Mock Fire practice and Evacuation Drill shall be performed periodically with participants of all the occupants of the industry.
13. A crew of trained Fire Man under an experience officer shall be maintained round the clock for safety of the Industry.
14. First-Aid Fire Fighting system shall be provided as per I.S. specification.
15. Arrangement shall have to be made for regular checking, testing and maintenance of all the fire fighting installation in the industry to keep them in perfectly good working condition at all the times.
16. If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. conduit pipes continuously bonded with the earth.
17. Electrical ducts shall be sealed vertically and horizontally at each floor level by fire resisting materials.
18. The Fire Safety Audit is to be conducted in a regular interval and to be recorded in the fire prevention maintenance register.
19. Violation of any recommendations which issued from this office previously this fire safety certificate shall be treated as cancelled and no renewal would be made.
20. This Fire Safety Certificate is valid for three years as per existing Govt. Notification and has to be renewed in due time.

Signature valid

Digitally Signed
Name: SHUVRAJ K. MAZUMDER
Date: 23-Sep-2022 10:54
Reason: Approved
Location: West Bengal

Divisional Fire Officer (Member Convenor),
Paschim Bardhaman
West Bengal Fire & Emergency Services


Principal
OOM International School
Durgapur


MANAGER
Manager
OOM International School
Durgapur